### **CP-31 Call Points Series Instructions**


#### **Specifications**

■ Dimensions: 87x93x55 mm (with clear plastic cover)

■ Contact resistance: 100mΩ

■ Contact Rating: Up to 5A 125/250 VAC

■ Plastic case: Green / Red / White / Yellow / Blue




#### **Specifications**


■ Dimensions: 87x93x55 mm (with clear plastic cover)


■ Contact resistance: 100mΩ

■ Contact Rating: Up to 5A 125/250 VAC

Plastic case: Green / Red / White / Yellow / Blue








Open the clear plastic cover. Insert the test key into the hole so that the plastic glass will tilt to one side and the switch will then change status from NC to NO. Remove the test key so that the switch reverts back to NC status.








Open the clear plastic cover. Press harder to break the plastic glass so that the switch will change status from NC to NO, triggering the connected device.


\* Remove the screw in the front to replace the plastic glass, and the switch will revert back to NC status.

# Wiring Diagram



Copyright © All rights reserved. P-MU-CT-PBT200-4 Ver.B Publish: 2011.08.11

### Wiring Diagram



Copyright © All rights reserved. P-MU-CT-PBT200-4 Ver.B Publish: 2011.08.11

## Wiring Diagram

